

Call 09 Bridge Joint Repairs at various locations throughout the District, known as Federal Aid Project No. STP-9999-07(014) / 107716301 in District 7.

Q1. How do you determine the project limits for litter for bridge locations all through District 7? Or do we just pick up litter on the bridges?

A1. The limits for litter and debris to be picked up will be from the ends of the bridge guardrail to the ROW line, including the bridge deck and debris resulting from cap cleaning operations.

Q2. What specific product are you looking for in regards to the Fiber Reinforced Polymer Patching Material? I have some products that are close to the specification, but not exact.

A2. Materials used should be from the Department's APL.